

TEST REPORT
48894D

Test Description: VOC content of Paints and Related Coatings

Test Method: ASTM D3960-05

Client and Project Information

Client: Saint-Gobain Construction Products SA (PTY) Ltd
Address: N1 Business Park, Cnr Old Jhb Samrand
Attention: France Nkadimeng
Tel: (012) 657 2800
Email: France.Nkadimeng@saint-gobain.com
Project number: N/A
Project name: N/A

Sample Information

Sample ID: WB11
Container: Plastic
Manufacturer: Saint-Gobain
Material Type: Tile Adhesive
Date Received: 2024/01/29
Date Analysed: 2024/02/02
Date Issued: 2024/02/02

PARAMETER

Weight of Water % (Ww)

Weight of Total Volatiles % (Wv)

Density of Product

RESULT

<0.1 %

<0.1 %

1 g/ml (approximate)

REFERENCE

ASTM D4017-02

ASTM D2369-10

As per Technical Data Sheet

TOTAL Volatile Organic Content

< 10 g/litre of product

Disclaimers

- 1) The results only relate to the test items provided, in the condition as received.
- 2) Calculated according to ASTM 3960-05 on ready to use product and including exempted solvents.
- 3) This report may not be reproduced, except in full, without the prior written approval of the laboratory.
- 4) A = Concentration outside calibration range, O = Outsourced analysis, UTD = Unable to Determine.

Francois Havenga
Authorised Signatory